



Small Duct High Velocity Heating, Cooling and Home Comfort Systems

Hi-Velocity System Design HE-Z/HE-B Series



Includes: System Design Unit Selection System Layout Unit Specifications



Features:

- Quiet Operation
- Constant Air Circulation
- Multi-Positional Air Handler
- Easy Installation & Maintenance
- Space Saving Small Diameter Ducts
- Zoning Capable right out of the Box!
- Many Attractive Vent Plate Options
- Superior Heating, Cooling and IAQ
- Eliminate Hot and Cold Spots



Manual-DES-Designing-the-HE-Z-HE-B-System-120121



Module DES Hi-Velocity System Design (2/10)

Hi-Velocity System Design

The following section is basic information needed for the designer. If not done already, this section should be read thoroughly before beginning installation.

IMPORTANT: A minimum of 4 (four) HE outlets or 8 (eight) 2" outlets per ton is required for all Hi-Velocity HE-Z air handlers. Any combination of 2" and/ or HE outlets can be used to meet this minimum.

Location

The multi-positional air handler can be installed in many different configurations. The air handler can be located in a Vertical, Horizontal, or Counter-Flow position.

Heat Loss/Gain

To size a Hi-Velocity System for a residence/commercial space, it is necessary to have an accurate heat loss/gain done for the structure. This will ensure the proper equipment is used for cooling and heating.

A heat loss/gain is done for each room, which will give a total BTUH load for the structure.

Room Name	BTUH Loss	BTUH Gain
Nook	8,326	5,233
Kitchen	2,539	1,688
Bath	1,114	693
Bed #1	2,667	1,592
Bed #2	3,845	2,165
Dining Rm.	5,109	3,802
Foyer	4,186	2,166
Family Rm.	5,859	4,001
Master Bed	9,326	6,046
M.Bath/WIC	2,786	1,193
Totals	45,757	28,579

Table DES-01 - Example Data for Fig. DES-02

The design factors used to achieve this heat loss/gain are shown on Fig. DES-02.

Low Water Temperature Systems

When running Hi-Velocity Systems from a low water temperature system (e.g. A hot water tank), care must be taken when designing and installing the system. Due to the lower water temperature there will be less BTUH's and therefore a lower supply air temperature, it is imperative that the water temperature is known at the design stage. If possible the highest temperature setting should be used, and a water tempering valve installed for the domestic use. The higher water temperature will increase system efficiencies, and the water tempering valve will reduce the risk of scalding. Since some areas have specific regulations regarding combo systems, please check your local building code for details on water tank temperatures, tempering valves, and pump timers.

Due to the lower air temperatures, when running the ductwork in an unconditioned space, the main plenum must be insulated and vapour barriered. Extra insulation should also be used in order to maintain a reasonable leaving air temperature at the vents.

Combination Hi-Velocity and Radiant

One of the benefits of using a hydronic system is the versatility that you have when designing the heating system. Radiant floor heating is an excellent system, but it does have limitations. You cannot have cooling, air filtration, and humidification with a straight radiant heating system. Similarly, sometimes a forced air system is not the only option available for a house, especially if it has a lot of ceramic tile or concrete floor areas.

In the sample house included, radiant floor heating may be unable to meet the requirements to heat the nook. With the Hi-Velocity System, we can heat this room, but would have an excessive number of outlets in a small area.





It is in rooms such as this that a hybrid system of both radiant heating and the Hi-Velocity System would be the optimum system to provide comfort conditioning. This will provide the home owner with good indoor air quality, and warm floor comfort (not as effective if carpet is laid down).

A common approach to a hybrid system is to heat the basement with radiant tubing. The main floor and 2nd floor if applicable would be heated with the Hi-Velocity System. A few outlets can also be placed in the basement to provide air circulation, and supplementary heating if required.



Module DES Hi-Velocity System Design (3/10)

Unit Selection

With the total load known for the structure, it is now possible to select the proper Hi-Velocity unit (Specifications - Pg. 9).

Table DES-02 – Selected Air Handler

HE-Z-70 H	
180°F	
45,757 BTUH	
28,579 BTUH	
HE = 10 2" = 20	
HE = 16 2" = 32	
2.5 ton	

Average BTUH Per Outlet

Once the unit has been selected, the average numbers of outlets can be determined (Specifications - Pg. 9). To determine the average number of vents, the minimum is added to the maximum and divided by two.

Example: (Using only 2" outlets)

(Min Outlets (20) + Max Outlets (32) / 2 = 26) * *Example shown using only 2" outlets

With the average number of vents known it is now possible to determine the average BTUH output per vent. Dividing the average number of outlets into the air handler output (Specifications - Pg. 9) will give an average BTUH output per vent.

Example:

BTUH per Outlet for HEATING

81,800 BTUH / 26 = 3,146 BTUH/OUTLET (3,146 BTUH delivery per outlet for Heating)

BTUH per Outlet for COOLING

30,000 BTUH / 26 = 1,154 BTUH/OUTLET (1,154 BTUH delivery per outlet for Cooling)

The BTUH per outlet is then used to figure out how many outlets are required for each room. As an example, here is a room by room load calculation for the house plan included (Fig. DES-02).

Room Name	BTUH LOSS	BTUH GAIN	If using 2" (51mm) Vents	If using HE Vents
Nook	8,326	5,233	4	2
Kitchen	2,539	1,688	2	1
Bath	1,114	693	1	1
Bed #1	2,667	1,592	2	1
Bed #2	3,845	2,165	2	1
Dining Rm.	5,109	3,802	3	2
Foyer	4,186	2,166	2	1
Family Rm.	5,859	4,001	4	2
Master Bed	9,326	6,046	5	3
M.Bath/WIC	2,786	1,193	1	1
Totals	45,757	28,579	26	15

Table DES-03 – Number Outlets Per Room

A room (Nook) that has a heat loss of 8,326 BTUH and a heat gain of 5,233 BTUH will need 4 vents.

Example:

4	4 x 3,14	6	BTUH	= 12,584	I BT	UH		
((12,584	>	8,326	Heating	req	uirements	satisfied)

4 x 1,154 BTUH = 4,616 BTUH

(4,616 < 5,233 Cooling requirements not satisfied)

The heating checks out but the cooling doesn't in this example. We allow a 10% variance on vent checks, which gives a little leeway with vent placement. Also with the kitchen being an adjoining room with an extra 620 BTUH it will help the nook maintain the desired temperature

Table	DES-04 -	System	Check
-------	----------	--------	-------

Heating Cooling Air Air House House Handler Handler BTUH BTUH Room Output Output Loss Gain Heating Cooling 12,584 Nook 8,326 4,616 5,233 Kitchen 6,292 2,539 2,308 1,688 Bath 693 3,146 1,114 1,154 Bed #1 6,292 2,667 2,308 1,592 Bed #2 6,292 2,165 3,845 2,308 Dining Rm. 9,438 5,109 3,462 3,802 6,292 Foyer 4,186 2,308 2,166 Family Rm. 12,584 5,859 4,616 4,001 Master Bed 15,730 9,326 5,770 6,046 M.Bath/wic 3,146 2,786 1,154 1,193 30,000 28,579 **Totals** 81,800 45,757

Not all rooms will check out for cooling as illustrated in Table DES-04, we allow a 10% variance on vent checks per room. The Main concern is the total unit output being higher than house BTUH loss. With the venturi action of the Hi-Velocity System the individual rooms will affect each other and help maintain the desired room temperature.

Difference in no. of Vents Req'd for Htg & Clg

There may be cases when the number of outlets needed for heating is significantly different than the amount needed for cooling. This is usually caused by a large appliance load or an excessive amount of windows. If this happens you will have to use the greater number of outlets to provide both heating and cooling for the room. The vents have dampers and can be adjusted for individual room comfort. In cooling mode the outlets must be in the fully open position or there will be a loss in performance and the efficiency of the system.





Module DES Hi-Velocity System Design (5/10)

System Layout

With the total vents known, the layout of the Hi-Velocity System can now be done. Start with individual vent placements (if you have not already read the section on Vents in System Design, please do so before starting). Then place the main plenum so the flex runs will be the shortest length possible. With the plenum placed, the flex runs can be drawn connecting the vent outlet to the main plenum.

Drawing Vent Placement

To demonstrate a vent layout, we'll place 4 two inch vents to properly condition the Nook (Fig. DES-03). From Table DES-03 we calculated that the Nook has a Heat loss/gain of 8,326/5,233, which will require 4 two inch vents to satisfy heating and cooling requirements.





With this room 3 two inch vents would have satisfied the heating requirements, but would not satisfy the cooling requirements. For the nook we need 4 two inch vents for cooling, so 4 two inch vents must be placed in the nook. The vents do have an adjustable damper and can be adjusted for individual room comfort if too much heating is being supplied. In cooling mode the outlets must be in the fully open position.

The outlets should be located where it is considered to be a "low traffic area". Typical areas are in the corner of a room, or to the side of a window or door. When the vents are properly located, the home owner can expect to have a nearly draft free home.

Once all the vents have been placed in each room, the main plenum can now be drawn. Figs. DES-04 and DES-05 shows where all vents have been located in the individual rooms.

Drawing the Plenum

For this layout we have chosen to use a Main Plenum with a 56/44 bullhead tee split. On one side 14 vents will used, while 11 will be used on the other. This is allowable as we can use a Bull Head Tee up to a 60/40 split. If the split is greater than 60/40, a Branch Tee should be used instead of the Bullhead Tee. See Module DUC - Installing Plenum and Branch Duct for Installation Instructions.

With a 56/44 split we will be able to reach all vents using standard 10' and 15' flex runs. If you have to extend the flex runs longer than 10', reference Table DES-05 for adjustment factors.

Table DES-05: De-rating Values

HE-Z Series				
Tubing Length	10′	15′	20′	25′
Adjustment Factor	0%	10%	20%	35%

The main plenum we choose to use is 8", it is not required to use 8" for the whole run. If space or cost is a concern, the main plenum can be reduced down to a smaller size. If reducing the plenum, reference Table DES-06 for allowable length and maximum number of vents for the size chosen. Never reduce at a bullhead tee, always reduce after the bullhead tee or you can lose approximately 20% of your airflow.

Table DES-06 – Duct Reduction

Duct Size	# of 2" (51mm) Vents	# of Vents (HE)	Max Length
4 " (102mm)	4	N/A	30' (9.14m)
5" (127mm)	6	3	40' (12.19m)
6" (152mm)	12	6	50′(15.24m)
7" (178mm)	18	9	60'(18.29m)
8 " (203mm)	30	15	70' (21.33m)
10" (254mm)	50	25	100' (30.48m)

Drawing the Flex Runs

Once the vents and plenum have been drawn in, the two may now be connected with the flexible branch duct. The minimum flex run is 10' (3.05m) and the maximum is 25' (7.62m)

Table	DES-07	- Allowable	Branch	Duct L	engths
-------	---------------	-------------	--------	--------	--------

Model	Min. Length	Max. Length
HE-Z Series	10′ (3.05m)	25' (7.62m)





PSB Zoning Design (HE-Z Series Only)

Please note: The HE-B Series Air Handlers can be used for zoning but may require the use of by-pass dampers or dump zones.

PSB Zoning

The PSB Board is compatible with most Forced Air Zoning Packages. Zoning control panels with a Recirculation Fan Option are strongly recommended, so as to utilize continuous air circulation for optimal Indoor Air Quality (IAQ) and Energy Efficiency. Independent testing has shown that utilizing the recirculation fan with the Hi-Velocity Systems VFD motor reduces total energy usage. This is due to less on/off cycling of AC and Heating equipment by constant de-stratification of the air.

Quick acting, spring shut dampers are not to be used with the PSB Board. Instead, it is suggested to use a slow acting electronic damper, which gives the PSB controller adequate time to adjust to variations in duct pressure.

Layout Design

There are three basic layout styles to be used with the PSB Controller: the Perimeter Loop/Branch (Fig. DES-06), the Main Plenum Branch (Fig. DES-07), and the Open Duct standard design (Fig. DES-08).

The **Perimeter Loop** layout is as the term implies. A perimeter loop of plenum duct is installed in the structure, from there branch tees are installed for each zone dependant on the zone size, and a zone damper is installed for each take-off/zone.

The **Main Plenum Branch** method is similar to a Perimeter Loop, in that you direct the main plenum to the area loads, with branch tees directing each zone to the outlets, once again installing zone dampers.

The **Open Duct** layout is the same concept that is used on Page 6. This method utilizes the branch split and bullhead tees planning of air flow, with each zone being individually controlled.

Each basic layout has it's typical applications. For example, the Perimeter Loop and Main Branch Layouts are best served doing multi-zones of 4 or more, with the Open Duct best servicing 2 -4 zones. Perimeter Loop works well in a single level application, while the Main branch is better suited for multi-level applications.

In some installations, it is necessary to reduce the size of the main plenum. Caution must be used when reducing plenum size, since smaller ducts can handle less number of outlets. Also keep in mind that once reduced, the main plenum cannot be increased again. The Branch Take Offs easily form to ducts in the 6" to 10" range; extra care must be taken with smaller sized ducts to ensure a proper air seal. For tee reductions, keep the tee to the full duct size, reducing only after the tee. Keep the length of the smaller duct sizes to a minimum, since the duct loss is much higher. If a hole saw will be used to drill the branch take-off holes, metal ducts are recommended to be 28 gauge steel.

Whichever method of zoning layout is utilized, it continues to be important for Indoor Air Quality that a certain amount of air is by-passed through each zone. This air recirculation is also important for Energy Efficiency, and even though the zone may not be calling for it, the recirc air will aid in overall living comfort.

Perimeter Loop (Fig. DES-06)

When designing the perimeter loop, first determine the system load and individual zones. Locate the air handler and vent outlets as per Page 5. Design the Perimeter Loop with the proper diameter 8" or 10" duct, as determined by the air handler unit. Use appropriate plenum duct size around the perimeter of the structure.

When sizing the branch zone plenum off the Perimeter Loop, use the Zoning Duct Reduction Guide. (Table DES-06). Total the outlets for each individual zone to determine the zone plenum duct diameter. Locate the tee servicing this zone to minimize the zone plenum duct, and run the plenum where it'll be possible to keep the AFD duct to 10' and 15' lengths. There is no minimum length on the Zone Main Plenum run. For maximum length allowed refer to the Zoning Duct Reduction Guide (Table DES-06).

Main Plenum Branch (Fig. DES-07)

The Main Plenum also requires that a comprehensive system load is completed, zones determined, air handler and outlets located as per this design manual. The Plenum duct is then located to direct the air to the loads at each zone, and elbow and tees can be located where required, as per this design manual.

The zone duct diameter is determined from the duct reduction guide and an appropriate balanced tee installed. Locate the tee servicing this zone to minimize the zone plenum duct, and run the plenum where it'll be possible to keep the AFD duct to 10' and 15' lengths. There is no minimum length on the Zone Main Plenum run. For maximum length allowed refer to the Zoning Duct Reduction Guide.

Open Duct System (Fig. DES-08)

The Open Branch layout utilizes this layout on Page 6 in its entirety, from load calculation to duct location. This method is best suited when 2 - 4 zones are utilized, by following the design manual and duct reduction guide if necessary. You will either branch or bullhead the tees to 1 or 2 zones, and continue the plenum to the furthest run, installing zone dampers where required.



Module DES Hi-Velocity System Design (8/10)

PSB Zoning Design Layouts

Table DES-07 - Zoning Duct Reduction Guide

Duct Size	# of vents 2" (51mm)	# of vents (HE)	Plenum Max. Length
5 " (127mm)	6	3	40' (12.2m)
6 " (152mm)	12	6	50' (15.2m)
7 " (178mm)	18	9	60' (18.3m)
8 " (203mm)	30	15	70' (21.3m)
10" (254mm)	50	25	100' (30.5m)

Main Plenum Branch Zone HE Outlet 2" Outlet HE and 2" Elex Duct		LEGEND
Zone Damper	₽₰०छ	Main Plenum Branch Zone HE Outlet 2" Outlet HE and 2" Flex Duct Zone Damper

Fig. DES-07 - Main Plenum Branch





Fig. DES-08 - Open Duct System



Matching Coils Refrigerant Coils RBM/RPM-E/RCM-50, 70,100 Chilled Water Coils WBM/WCM-50, 70, 100 Hot Water Coils HWC-50, 70, 100 Electrical Coils ESH/VESH-650, 750, 1100



HE-Z/HE-B Series Specifications

Hi-Velocity Air Handler w/ VFD Motor



	HE-Z/HI	E-B-50/51	HE-Z/H	E-B-70/71	HE-Z/HE	-B-100/101
Hot Water Heating ⁽¹⁾	2 Ton Airfl	OW (7.0 kW)	3 Ton Airfle	OW (10.6 kW)	5 Ton Airflow (17.6 kW)	
Coil Type	6 Row/	'10 FPI	6 Row/	/10 FPI	6 Row	/10 FPI
Max. BTUH @ 190°F E.W.T. (kW @ 88°C)	59,400	(17.4 kW)	89,200	(26.1 kW)	134,000	(39.3 kW)
Max. BTUH @ 180°F E.W.T. (kW @ 82°C)	54,500	(16.0 kW)	81,800	(24.0 kW)	122,900	(36.0 kW)
Max. BTUH @ 170°F E.W.T. (kW @ 77°C)	49,600	(14.5 kW)	74,400	(21.8 kW)	111,800	(32.8 kW)
Max. BTUH @ 160°F E.W.T. (kW @ 71°C)	44,600	(13.1 kW)	67,100	(19.7 kW)	100,700	(29.5 kW)
Max. BTUH @ 150°F E.W.T. (kW @ 66°C)	39,700	(11.6 kW)	59,700	(17.5 kW)	89,700	(26.3 kW)
Max. BTUH @ 140°F E.W.T. (kW @ 60°C)	34,700	(10.2 kW)	51,800	(15.2 kW)	78,400	(23.0 kW)
Max. BTUH @ 130°F E.W.T. (kW @ 54°C)	29,700	(8.7 kW)	44,700	(13.1 kW)	67,100	(19.7 kW)
Max. BTUH @ 120°F E.W.T. (kW @ 49°C)	24,800	(7.3 kW)	37,400	(11.0 kW)	56,200	(16.5 kW)
Max. BTUH @ 110°F E.W.T. (kW @ 43°C)	20,100	(5.9 kW)	30,300	(8.9 kW)	45,500	(13.3 kW)
GPM Flow Ratings (L/s Flow Ratings)	5 (0.3	2 L/s)	7 (0.4	4 L/s)	10 (0.	63 L/s)
Pressure Drop in Ft. H ₂ O (Drop in KPa)	3 (8.9	6 KPa)	6.5 (19	9.4 KPa)	6.8 (20).3 KPa)
Chilled Water Cooling ⁽¹⁾	WBM/W	/CM-50	WBM/W	VCM-70	WBM/W	/CM-100
Coil Type	6 Row/	'10 FPI	6 Row/	/10 FPI	6 Row	/10 FPI
WBM/WCM Modules in Cooling Mode	Total	Sensible	Total	Sensible	Total	Sensible
Max. BTUH @ 48°F E.W.T. (kW @ 8.9°C)	19,300 (5.7 kW)	13,700 (4.0 kW)	27,000 (7.9 kW)	19,200 (5.6 kW)	42,100 (12.3 kW)	30,300 (8.9 kW)
Max. BTUH @ 46°F E.W.T. (kW @ 7.8°C)	20,900 (6.1 kW)	14,200 (4.2 kW)	29,400 (8.6 kW)	20,000 (5.9 kW)	45,800 (13.4 kW)	32,100 (9.4 kW)
Max. BTUH @ 44°F E.W.T. (kW @ 6.7°C)	22,600 (6.6 kW)	14,900 (4.4 kW)	31,800 (9.3 kW)	21,000 (6.2 kW)	49,500 (14.5 kW)	33,700 (9.9 kW)
Max. BTUH @ 42°F E.W.T. (kW @ 5.6°C)	24,200 (7.1 kW)	15,700 (4.6 kW)	34,000 (10.0 kW)	21,800 (6.4 kW)	53,200 (15.6 kW)	35,100 (10.3 kW)
Max. BTUH @ 40°F E.W.T. (kW @ 4.4°C)	25,800 (7.6 kW)	16,300 (4.8 kW)	36,400 (10.7 kW)	23,000 (6.7 kW)	56,800 (16.6 kW)	36,400 (10.7 kW)
WBM/WCM Modules in Heating Mode	Total		To	tal	To	tal
Max. BTUH @ 150°F E.W.T. (kW @ 66°C)	39,700 (11.6 kW)		59,700 (17.5 kW)		89,700 (26.3 kW)	
Max. BTUH @ 140°F E.W.T. (kW @ 60°C)	34,700	(10.2 kW)	51,800	(15.2 kW)	78,400	(23.0 kW)
Max. BTUH @ 130°F E.W.T. (kW @ 54°C)	29,700	(8.7 kW)	44,700	(13.1 kW)	67,100	(19.7 kW)
Max. BTUH @ 120°F E.W.T. (kW @ 49°C)	24,800	(7.3 kW)	37,400 (11.0 kW)		56,200	(16.5 kW)
Max. BTUH @ 110°F E.W.T. (kW @ 43°C)	20,100	(5.9 kW)	30,300	(8.9 kW)	45,500	(13.3 kW)
GPM Flow Ratings (L/s Flow Ratings)	5 (0.3	2 L/s)	7 (0.4	4 L/s)	10 (0.	63 L/s)
Pressure Drop in Ft. H ₂ O (Drop in KPa)	3 (8.9	7 KPa)	6.5 (19	9.4 KPa)	6.8 (20).3 KPa)
Refrigerant Cooling ⁽¹⁾	RBM/RPM-	E/RCM-50	RBM/RPM-	-E/RCM-70	RBM/RPM-	E/RCM-100
RBM/RPM-E/RCM Modules BTUH Refrigerant TX Cooling	1.5 - 2. (5.3-7.0	0 Tons) kWh)	2.5 - 3. (8.8-10.	.0 Tons .6 kWh)	3.5 - 5 (12.3-17	.0 Tons 7.6 kWh)
Electrical Heating	ESH/VE	SH-650	ESH/VE	SH-750	ESH/VE	SH-1100
Kilowatt Range (240v)	5 - 15 kW /	10 - 15 kW	5 - 18 kW /	10 - 18 kW	10 - 2	23 kW
Specifications	HE-Z/HE	-B-50/51	HE-Z/HE	-B-70/71	HE-Z/HE-	B-100/101
Max Rated CFM @ 1.2" E.S.P. (L/s @ 298 Pa)	500 (2	36 L/s)	750 (3		1250 (590 L/s)
Voltage	115/230/1/50/6	50 FLA 8 amp	115/230/1/50/6	50 FLA 8 amp	115/230/1/50/6	50 FLA 8 amp
Nominal Operating Amperage	4 Ar	nps	6 Ar	mps	8 Amps	
Integral Surge and Fuse System	Ye	25	Ye	25	Yes	
Horse Power - Watts	3/4hp -	· 310W	3/4hp - 530W		3/4hp - 720W	
Motor RPM	Variable		Varia	able	Varia	able
Supply Air Size	8" Round	d (203mm)	8" Round	d (203mm)	10" Roun	d (254mm)
Supply Maximum Length ⁽²⁾	70′ (2	(1.3m)	80′ (2	24.4m)	100′ ((30.5m)
Return Size Needed	12" (120 in ²)	(305mm/774cm ²)	12" (120 in ²)	(305mm/774cm ²)	14" (1	68 in ²)
Minimum Outlets ⁽³⁾	6 (HE)	12 (2")	10 (HE)	20 (2")	14 (HE)	28 (2")
Maximum Outlets	13 (HE)	26 (2")	18 (HE)	36 (2")	30 (HE)	60 (2")
Shipping Weight (no coil)	85 lbs	(38.6 Kg)	97 lk	OS (44 Kg)	111 lbs	(50.3 Kg)
		, <u>,</u>		1 "		1 "
Air Handler Size (L x W x H) (Add $2^{1}/_{2}$ inches to height for collars)	14 ¹ ⁄2″ x 18 ¹ (368mm x 464)	/4¨ x 32 ⁵ /16″ mm x 821mm)	19 ¹ /2" x 18 ¹ (495mm x 464	¹ /4 ^{°°} x 32 ⁵ /16″ mm x 821mm)	25 ¹ /2" x 18 (648mm x 464	¹ /4 ^{°°} x 32 ⁵ /16″ mm x 821mm)

⁽¹⁾ Heating specs are rated at 68°F E.A.T., Cooling specs are rated at 80°F/67°F dB/wB

⁽²⁾ Maximum length is from the unit to the supply run end cap. More than one run per unit is allowable.

⁽³⁾ Minimum of four HE outlets per ton of cooling needed. (2" Duct = Minimum eight 2"outlets per ton)

BTUH - British Thermal Units per Hour E.W.T. - Entering Water Temperature GPM - US Gallons per Minute L/s - Litres per Second CFM - Cubic Feet per Minute F.L.A. - Full-Load Amperage RPM - Revolutions per Minute E.S.P. - External Static Pressure E.A.T. - Entering Air Temperature dB/wB - Dry Bulb/Wet Bulb Energy Saving Products Ltd, established in 1983, manufactures the Hi-Velocity Systems[™] product line for residential, commercial and multi-family markets. Our facilities house Administration, Sales, Design, Manufacturing, as well as Research & Development complete with an in-house test lab. Energy Saving Products prides itself on Customer Service and provides design services and contractor support.

For all of your Heating, Cooling and Indoor Air Quality needs, the Hi-Velocity System is the right choice for you!



Small Duct Heating, Cooling and IAQ Systems

Build Smart, Breathe Easy

Hi-Velocity HE-Z Air Handlers, Green Technology





Phone: 780-453-2093 Fax: 780-453-1932 Toll Free: 1-888-652-2219

www.hi-velocity.com